

2/41



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/School/ 629

Dated: 12/09/2024

To,

The Principal,
C.R.P.F Public School,
Sec-14, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o C.R.P.F Public School, Sec-14, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 20.07.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 30.08.2024, in presence of **Mr. Sanjeev Kapoor** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel provided but not functional.
2. Terrace Fire pump with capacity 450 & 180 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000

