



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

103
7/09/24
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/School/NDZ/2024/ 611

Dated: 10/09/2024

To,

The Principal,
Ganga Genesis Elementary School
D - 98, Gali no. 11, Jagjeet Nagar,
Delhi - 110053.

Subject: - Regarding grant of Fire Safety Certificate in r/o Ganga Genesis Elementary School located at D - 98, Gali no. 11, Jagjeet Nagar, Delhi - 110053.

Sir,

This has a reference to your Outdoor Diary No. 5238 dated 13.08.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/09/2024 in the presence of Mrs. Karuna Devi (Manager) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. The Premises in not accessible to fire engines.
2. One staircases of width 1.35 meter is provided instead of required of two having width of 1.50 meter each.
3. The width of door size is 1.0 meter against the requirement of 1.20 meter.
4. Hose reel hose not provided.
5. MOEFA not provided.
6. Terrace pump of capacity 450LPM is not provided.
7. Overhead of capacity 10,000 liters is not provided.
8. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, David Modal Senior Sec. School located at Main Road Tukmirpur, Delhi - 110090.