



No. F6/DFS/MS/School/NDZ/2024/ 612

Dated: 10/09/2024

To,

The Manager,
Ganga Happy Secondary School
E – 301, Jagjeet Nagar, New Usmanpur,
Delhi - 110053.

Subject: - Regarding grant of Fire Safety Certificate in r/o Ganga Happy Secondary School located at E – 301, Jagjeet Nagar, New Usmanpur, Delhi – 110053.

Sir,

This has a reference to your Outdoor Dairy No. 5237 Dated 13/08/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/09/2024 in the presence of Manager and observed that building comprised of ground plus three upper floors

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers are empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Overhead water storage tank capacity 2,000 liters is provided against requirement of 10,000 liters.
5. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, Ganga Happy Secondary School located at E – 301, Jagjeet Nagar, New Usmanpur, Delhi – 110053.