

c/81

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 575

Dated:-11.09/2024

To,

The Manager,
M/S Hotel De-Hocks Dx. Guest House,
8/7, D.B.G. Road, Pahar Ganj,
New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Hotel De-Hocks Dx. Guest House located at 8/7, D.B.G. Road, Pahar Ganj, New Delhi.

Sir,

This has reference to your online ID No. 2024031903243 dated 13.08.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 30/08/24 in presence of Mr. Jasvir and following shortcomings were observed:

1. Smoke management system is not provided
2. CO detectors found nonfunctional.
3. Further building plan as uploaded on the portal does not match with the actual shape of guest house building.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.