

C/23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 528

DATED: 12 / 09 / 2024

To,

Sh. Rajesh Aggarwal,
Metro Bhawan, Fire Brigade Lane,
Barakhamba Road, New Delhi - 110001.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Metro station, Located at Sector – 13, Dwarka. New Delhi.

Sir,

Please refer to letter No. DMRC/O&M/Fire/NOC/L-3/2024/09 dated 09/08/2024 on the subject cited above. In this connection it is to inform to you that the above said premises has been inspected by the officer concerned of this department on 09/09/2024 in presence of Sh. Sanyam Jain (Manager Fire) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Fire Check Doors are found locked at some places. It must be kept free from lock & keys/ bolts.
2. Hoses & Branches are found missing at some places.
3. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,



(Anil Garg)
Director
Delhi Fire Service

Ok  

Copy to:-

Sh. Sanyam Jain (Manager Fire), Metro station, Sector – 11, Dwarka. New Delhi.