

C/22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024 School | 617

Dated: 10 / 09 / 2024

To,

The Principal,  
New Galaxy Public School,  
Plot no- 4, E block, Qutab vihar phase 1,  
Sector -19 dwarka, New Delhi-110071.

**Subject: Issuance of Fire Safety Certificate in r/o New Galaxy Public School located at Plot no- 4, E block, qutab vihar phase 1, Sector -19 dwarka, New Delhi-110071.**

Sir,

Please refer to Form I, dated 24/07/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 21/08/2024 in the presence of Sh. Sudhir Singh (Owner) from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. 1<sup>st</sup> & 2<sup>nd</sup> Floor found being used for school activities without providing fire safety provisions .
2. Two staircase of 1.5m width each not provided.
3. Exit Signage's found removed at some places.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
Director,  
Delhi Fire Service

Copy to:

1. The Directorate of Education Old Secretariat Delhi – 110054