



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

clb

No. F6/DFS/MS/2024/School/ 616

Dated: 10/09/2024

To

The Chairmen
Shree Ram International School,
Khasra No- 16/3, Gali No-9, Block-D,
Nathu Colony, Nathupura, Delhi-84.

Sub: - Regarding grant of fire safety certificate in r/o Shree Ram International School located at Khasra No- 16/3, Gali No-9, Block-D, Nathu Colony, Nathupura, Delhi-110084.

Sir,

Please refer to your letter no- nil dated 27.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 03.09.2024 in the presence of Sh. R.B. Sharma (Incharge) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premises is comprised of ground & 03 upper floors only. The observations/ shortcomings made are as under:-

1. There is two staircase provided width of 1.50m each only one staircase continues from ground to terraces level and second staircase continues from ground to 3rd floor only needs both staircase required continues from ground to terraces level.
2. Fire extinguisher is provided but not functional.
3. Hose reel hose is provided but not functional and damaged condition.
4. Terrace level fire pump capacity of 450lpm is provided but not functional and damaged condition.
5. Terrace level fire water tank 4400ltr is provided against the requirement of 10,000ltr.
6. Exit & floors signage's not provided at strategic location in the school building.
7. Standby power supply is not provided.
8. As built plan of the school duly signed by registered architect & owner shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

(Ajul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.