No.F6/DFS/MS/School/SZ/2024/ 621

To

Mrs. Harushi Kataria (Director), R. K. Kinder Garten (Pre-School & Daycare), F-69, 70, 71, Jawahar Park, Khanpur, Devli Road, New Delhi-80.

Regarding issuance of Fire Safety Certificate in r/o R. K. Kinder Garten (Pre-School & Sub:-Daycare) located at F-69, 70, 71, Jawahar Park, Khanpur, Devli Road, New Delhi-80.

Sir,

With reference to letter bearing outdoor diary no.2632 dated 07.06.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.09.2024 in the presence of Mrs. Harushi Kataria (Director) and it was observed that the school is running on Basement (vacant) + Ground + 01 upper floor only of the building which is comprised of Basement + Ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. Garments manufacturing factory was found running at 2nd & 3rd floor of the same building using common means of escape. Same cannot be permitted to operate in a school building and

must be removed.

2. Electrical meters must be removed from the main staircase of basement.

3. 07 nos. of fire extinguishers not provided.

4. Automatic Sprinkler System not provided in the basement (area more than 200 m²).

5. Fire pump of 450 LPM with head 40 m not provided.

6. Terrace water tank of 5,000 liters not provided (for sprinkler system).

7. Exit signages not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

al Garg) Director

Delhi Fire Service

Copy to:-.

1. The Dy. Director of Education, GNCT of New Delhi DISTT. South Sector-3, R.K. Puram, New Delhi-22.