

c-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/Educational/2024/SZ/ 291

Dated: 10/09/2024

To,

Sh. Ajit Chaudhary (Secretary),
Surajmal Memorial Education Society (Regd.),
C-4, Janak Puri, New Delhi-110058.

Sub: Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Surajmal Memorial Education Society (Regd.), C-4, Janak Puri, New Delhi-110058.

Sir,

Please refer to your letter SMES/2024/171/914 dated 02.08.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building on dated 29.08.2024 to verify the fire safety arrangements in accordance with the directives letter no. F6/DFS/MS/BP/2002/662 dated 22.04.2002 & F.6/DFS/MS/BP/2011/2085 dated 25.08.2011. At the time of inspection Sh. Shitansu Sharma (Engineer) was present and it was observed that the building is comprised of two blocks namely MSI block & MSIT Block. MSI Block is comprised of ground plus Four upper floors & MSIT Block is comprised of basement ground plus six upper floors and have following shortcomings were observed: -

1. Basement of MSIT block use for book bank/library, staff room, engineering workshop & class rooms etc. instead of storage.
2. Internal road is blocked by vehicle parking.
3. First hose reels provided but found not functional.
4. Internal & yard hydrant provided but not functional.
5. All pumps provided with underground tank and terrace pump are found not functional.
6. Overhead water storage tank found provided 20,000 ltrs. instead, requirement of 30,000 ltrs.
7. Exits signages are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running educational building in absence of requisite fire safety arrangements shall be at the risk & liability of the management of institute.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Executive Engineer (Bldg.), MCD, 9th floor, Civic Centre, Minto Road, New-Delhi- 02.
: - for information regarding use of basement.