



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/05

No. F6/DFS/MS/2024/School/ 619

Dated: 12/09/2024

To

The Principal
Uttam Public School,
Kh. No- 35/24, 38/4, Vill. Lampur,
Near Bus Stand, Delhi-110040.

Sub: - Regarding grant of fire safety certificate in r/o Uttam Public School located at Khasra No- 35/24, 38/4, Village, Lampur, Near Bus Stand, Delhi-110040.

Sir,

Please refer to your letter no- nil dated 20.08.2024 received vide outdoor dairy no-5437 dated 20.08.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 02.09.2024 in the presence of Mrs. Anita Saini (Principal) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premises is comprised of ground & first floor and 2nd floor one room only but school is running is ground & first floor only. The observations/ shortcomings made are as under:-

1. There is two staircase provided width of 1.50m & 1.30m, only one staircase continues from ground to terraces level and second staircase continues from ground to 2nd floor only needs both staircase required continues from ground to terraces level.
2. The school class room doors size is provided 90cm against the requirement of 1.20m.
3. Fire extinguisher is not provided.
4. Hose reel hose is not provided.
5. Terrace level fire pump capacity of 450lpm is not provided.
6. Terrace level fire water tank capacity of 10,000ltr is not provided..
7. Exit & floors signage's is not provided at strategic location in the school building.
8. Standby power supply is not provided.
9. One pucca room found construction at second floor which is being used for storage of books and other article, shall be demolished/removed.
10. As built plan of the school duly signed by registered architect & owner shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

9/90