



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/9/24  
आशादीन  
अपु मदीलव

No. F6/DFS/MS/School/NDZ/2024/ 635

Dated: 17/09/2024

To,

The Principal,  
MCD Primary School,  
Gamari - II, Shahdara,  
North Delhi-110053.

**Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Gamari - II, Shahdara, North Delhi-110053.**

Sir,

This has a reference to your outdoor dairy no.6029 dated 04/09/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/09/2024 in the presence of Mr. Ashok Sharma (Principal) and observed that building comprised of Ground plus two upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-aid-Hose Reels provided but not functional.
2. Fire pump of 450 LPM provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Your faithfully,

(ATUL GARG)  
DIRECTOR

OK (u) DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD, 419, Udyog Sadan, Patparganj, Industrial Area, Delhi - 110092.
2. The Principal, MCD Primary School located at Gamari - II, Shahdara, North Delhi-110053.