



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का  
अमृत महोत्सव

Dated: 3/09/2024

No. F6/DFS/MS/EH/NDZ/2024/ 396

To,

Mr. Kamal Sharma (Owner),  
Captain Katora (A unit of India Core Kitchen)  
Property No. C- 10/28, Main 100 Foot Road,  
Kabir Nagar, Shahdara, Delhi – 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Captain Katora A unit of India Core Kitchen located at Property No. C- 10/28, Ground and first floor Main 100 Foot Road, Kabir Nagar, Shahdara, Delhi – 110094.**

Sir,

This has a reference to your MHA Portal application No. 202481612787 dated 22/08/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 09/09/2024 in the presence of Mr. Kamal Sharma (Owner) and observed that building comprised of Basement (store) + Stilt (Parking) + Upper ground plus three upper floors. (Restaurant running on upper ground & first floor only).

**Following shortcomings were observed during time of inspection:**

1. The width of door size is 0.92 meter & 1.30 meters against the requirement of 1.50 meter each.
2. Fire check door not provided.
3. Smoke Management System not provided in upper floors.
4. First-aid-Hose Reels provided but not functional.
5. MOEFA provided but not functional
6. Internal Hydrants provided but not functional
7. Fire pump of 450 LPM provided but not functional.
8. Exit & floors Signage's not provided at strategic location in the building.
9. Standby Power Supply not provided

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Owner, Captain Katora A unit of India Core Kitchen located at Property No. C- 10/28, Ground and first floor Main 100 Foot Road, Kabir Nagar, Shahdara, Delhi – 110094.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi - 110024.  
MHA portal ID - 202481612787 dated 22/08/2024.