

c 109

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F6/DFS/MS/BNQT/WZ/2024/ 110
To,

Dated: 12/09/2024

The Dy. Health Officer (West Zone),
NDMC, Public health department,
Karol Bagh Zone, Anand Parbat,
New Delhi -110005.
Email Id : - (dhowest zone@gmail.com).

Subject: **Regarding Renewal of NOC from fire safety point of view in respect of M/s Luxuriant Banquet LLP, located at Plot No. 9A, GF,FF Rama Road, Najafgarh Road, Industrial Area, New Delhi-110015.**

Sir,

Please refer to your online application no. 2024081812839 dated 20/08/2024 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 09/09/2024 in the presence of Sh. Kunwar Bhardwaj (Owner) to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said Banquet Hall is running at Ground Floor & 1st floor in a building comprised of Basement + Ground + Mezzanine + 01 upper floors was issued FSC vide letter no. F6/DFS/MS/BNQT/MN/2021/423 dated 31/08/2021. Fire Safety arrangements such as Fire Extinguishers, First -Aid Hose reel, Terrace pump, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. First Aid Hose Reel is provided but not functional.
2. Smoke & Heat Detectors provided but not functional.
3. Internal Hydrant is provided but not functional.
4. Ground level Main Pump 2280 LPM, Stand by Pump 2280 LPM, Jockey pump 180 LPM & terrace level pump capacity of 900 LPM is provided but not functional.
5. Over Head Water Storage Tank capacity of 10,000 ltrs is provided but found empty.
6. Exit signages are found removed.


In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Aful Garg)
Director

Copy To:-

1. The Owner/Occupier of M/s Luxuriant Banquet LLP, located at Plot No. 9A, GF,FF Rama Road, Najafgarh Road, Industrial Area, New Delhi-110015.


7/10/24
09/09/2024