

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 584
To

Dated: 12/09/2024

The Addl. Commissioner of Police,
Lic/Unit, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Royal Castle Grand located at D-616, D-Block, C.R Park, New Delhi-110019.

Sir,

This is in reference with MHA Portal ID 2022021502226 dated 13/08/2024 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 10.09.2024 in the presence of Mr. Sunil Verma (owner) of the Guest House to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Basement is being used for commercial activity other than storage

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

gk w