

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F. 6. / DFS / MS / BP /2024/ 488

Dated: 02/09/2024

To,

The Executive Engineer, (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor Civic Centre, Minto Road,  
New Delhi-110002.

**Sub: Online building plans in r/o National Law University at Pocket-1, Golf Course Road Sector-14, Phare-II, Dwarka, New Delhi - 110075.**

Sir,

Please refer your online ID No. 10117752 dated 19.08.2024 on the subject cited above. In this connection it is to inform you that the referred online building plans have been examined by this department from life/fire safety point of view and observed following shortcomings:

1. Occupancy is not mentioned in CAF in accordance with clause 1.4.75 of UBBL – 2016.
2. Travel distance from the dead end of corridor is not meeting the requirement of clause 7.8.2 of UBBL – 2016.
3. Fire tower is not designed in accordance with clause 9.3.13 of UBBL – 2016.

Therefore, plans are rejected.

Yours faithfully

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

2/9/24