



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F. 6. / DFS / MS / BP / 2024/ 536

Dated: 19 /09/2024

To,

The Medical Superintendent,
B M Gupta Hospital Pvt. Ltd.,
H-11 to 15, Uttam Nagar,
New Delhi -110059.

Sub:- Submission of updated Blueprint and structure Height certificate of B.M. Gupta Hospital Pvt. Ltd. situated at H – 11 to 15, Uttam Nagar, New Delhi – 110059.

Sir,

Please refer your letter No. Nil dated 11.07.2024 on the subject cited above. In this connection it is to inform you that as built plan of said hospital, as provided by you, has been examined and observed following shortcomings:

1. The plan is not to scale.
2. Width of access road is not meeting the requirement as required.
3. Width of staircases is not meeting the requirement of UBBL – 2016.
4. Width of corridor is not meeting the requirement of UBBL – 2016.
5. Width of main exit doors is not meeting the requirement of UBBL – 2016.
6. Width of exit, patient / ward rooms is not meeting the requirement of UBBL – 2016.
7. Electrical room is not protected by FCD.
8. Staircases, serving from basement, are not segregated on ground floor.
9. Exit arrangement is not meeting the requirement of clause 7.5.10 of UBBL – 2016.
10. Entry to staircases / lift lobby is not through Fire Check Doors.
11. Fire protection arrangements such as underground fire tank, overhead fire tank, hose reel, fire extinguishers etc. as stipulated in NBC-Part-4 are not marked on the plan.
12. Rooms are shown on terrace, but its floor plan is not provided.

Therefore, plan is returned to you in original with request to rectify above shortcomings and re-submit the plan for further consideration in the matter.

Encl.: As above

Copy to:

The Medical Superintendent, Nursing Homes,
Directorate General of Health Services,
Govt. of NCT of Delhi (Nursing Home Cell),
3rd Floor, Delhi Government Dispensary Building,
S-1, School Block, Shakarpur, Delhi – 110092.

Yours faithfully


(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Ph. 011-23412025

