

chb

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2024/ 648

Dated: 20/09/2024

To

The Principal,
Commercial Sr. Sec. School,
24, Darya Ganj, Delhi - 110002.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Commercial Senior Secondary School, 24, Darya Ganj, Delhi -110002.**

Sir,

This has reference to your letter no. CSSS/2024/1023 dated 03.08.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 07.09.2024 in the presence of Mr. Naresh Kumar Sharma (In-charge) and it was observed that building is comprised of ground + 02 upper floors + 01 Auditorium. During the inspection, following shortcomings were observed:-

1. First aid hose reel provided but not functional.
2. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

10/09/24
13/9