

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2024/SZ/592

Dated: 19/09/2024

To

The Joint Commissioner of Police
(Lic/Branch, 1st Floor, Police Station Defence Colony,
New Delhi 110049)

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Decent Suites located at
Plot No A-292, Mahipalpur Extn. New Delhi 110037.

Sir,

This has reference to with **MHA Portal ID 2024082012901 dated 20/08/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 17.09.2024 in the presence of Mr. Jai Sen (Manager) and observed that building comprised of Basement, Ground + 03 upper floors and following shortcomings were observed during inspection :

1. There are two staircase having width of 1.50 mtr & 1.10 mtr (through rooms) against the required two staircase having width of 1.50 mtr each.
2. Kitchen also running under the staircase, which needs to be removed.
3. Terrace level fire fighting pumps capacity 450 LPM not provided.
4. Overhead tank capacity 10,000 ltrs not provided.
5. Exit Signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

MJ