



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2024/Indl./ 534

Dated 19/09/2024

To

The Authorized Signatory
Divine Auto Pvt. Ltd at Plot No-26,
Rajasthani Udhyog Nagar, G.T. Karnal,
Road, Industrial Area, Delhi-110033.

Sub: Regarding issuance of Fire Safety Certificate in r/o Divine Auto Pvt. Ltd located at Plot No-26, Rajasthani Udhyog Nagar, G.T. Karnal Road, Industrial Area, Delhi-110033.

Sir,

Please refer to your letter no. nil dated 31.08.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 09.09.2024 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no F6/DFS/MS/BP/2024/131 dated 02.05.2024. At the time of inspection Sh. Ashish (Supervisor) was also present at site. During the course of the inspection, it is observed that the building is comprised of ground & first floor. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors not provided.
2. Smoke ventilation system is not provided in the building.
3. Terrace level fire water tank capacity of 25,000ltr is provided against the requirement of 50,000ltr.
4. Exit signage's and floor signage is not provided at strategic location in the building.
5. Both staircases are not concealed in a brick walls from ground to terrace level.
6. Building is not constructed as per approved sanction plan.

Keeping in view of above, issuance of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of industry is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:011-23414000

Copy to:-

1. The Dy. Commissioner of Factory licensing, SDMC 3rd, Floor, Civic Centre
Minto Road, Delhi-110002.