



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



0123 DFA+FI

No. F6/DFS/MS/School/NDZ/2024/ 642

Dated: 19 / 09 / 2024

To,

The Principal,
Hans Raj Smarak School,
J-5/2, Krishna Nagar,
Delhi - 110051.

Subject: - Regarding grant of Fire Safety Certificate in r/o Hans Raj Smarak School, located at J-5/2, Krishna Nagar, Delhi - 110051.

Sir,

This has a reference to Email dated 27/08/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12/09/2024 in the presence of Mrs. Anju Sharma (Principal) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. All fire extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Overhead tank of 6,000 liters capacity is provided against the requirement of 10,000 liters.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.