



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/60



No: F.6/DFS/MS/School/2024/WZ/ 644

Dated: 19/09/2024

To,

The Principal,
New Star Public School,
21, Central Market, Ashok Vihar,
Delhi-110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o New Star Public School located at 21, Central Ashok Vihar, Delhi- 110052.

Sir,

This has reference to your letter no. nil dated 28.08.2024 received through outdoor diary no. 5767 dated 28/08/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was visited by officer concerned of this department on 04.09.2024 to see the compliance of shortcomings issued vide letter no. F6/DFS/MS/2011/1661 dated 20/07/2011. Smt. Khusboo (Teacher) was present at the time of inspection.

During the course of inspection it was observed that school is running at First floor only in a building comprised of Basement, Ground, Mezzanine and First Floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Alternate staircase of 0.75 m width found not provided.
2. First aid hose reels found not provided.
3. Terrace level pump of 220 lpm discharge found not provided.
4. Overhead tank of 2500 ltrs capacity exclusively for fire pump found not provided.
5. Exit signage's not provided.
6. Electric meters installed inside the staircase have to be removed immediately to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully


(Atul Garg)
Director

Ph. 011-23414000




13/9

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.