

465

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2024/ 539

Dated 20/09/2024

To,

Sh. Hari Shankar Das,
Dy. Genl. Manager (EM),
FCI Hqrs, New Delhi.

Sub:- Regarding renewal of FSC in r/o Food Corporation of India at Plot No. 16-20, Barakhamba Lane, New Delhi.

Sir,

This has reference to your letter no. nil dated 28.08.2024, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 09/09/2024 in the presence of Sh. Hari Shankar Das, and the following shortcomings were observed:-

1. Alternate staircase is not serving to 11,12th and 13th floor.
2. Fire checks door found removed.
3. Detectors found nonfunctional.
4. Fire extinguisher due for refilling.
5. Hose reel & Hydrants found nonfunctional and not provided in basement.
6. Sprinklers not provided in basement.
7. Smoke management system not provided in basement.
8. Lift signage found removed at some location.
9. Electrical wiring found hanging haphazardly, which may lead to fire hazard.
10. Pruning of trees for easy access to fire tender is required

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.