

c/133

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024 | College | 325

Dated: 23/09/2024

To,

The Principal,
Sky vision Welfare Society
Sector-9, Dwarka, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Sky vision Welfare Society Located at Sector-9, Dwarka, New Delhi.

Sir,

Please refer to letter No. nil dated 12/08/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 11/09/2024 in the presence of Sh. Manoj Kumar (Accountant) from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. Passage to 2nd staircase found blocked at 3rd floor.
2. Fire Check doors found removed at some places.
3. Smoke exhaust system found non functional.
4. Hose reel hose & hydrants found nonfunctional.
5. PA system & MOEFA found nonfunctional.
6. Detectors system found nonfunctional.
7. Automatic Sprinkler system found nonfunctional in basement.
8. Terrace pumps found nonfunctional.
9. Terrace tank found damaged.
10. Pressurization system for lift found nonfunctional.
11. The lift found being run up to basement without provided in fire safety & life measures.
12. Refused Area found not clear.
13. Kitchen has been setup at stilt floor.
14. Canteen being found running in basement

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

Copy to:

1. The Directorate of Education Old Secretariat Delhi – 110054.
2. The Joint Director (Building), DDA, Vikas Sadan, New Delhi.

(Atul Garg)
Director,
Delhi Fire Service

o/c

11/09/24