

c/03

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 653

Dated: 24/09/2024

To,

The Owner/occupier,
Small Star School of Education with Technology,
(A unit of Human Care International), Defence Enclave,
Main Dichau Road, Najafgarh, New Delhi-110043.

Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Small Star School of Education with Technology (A unit of Human Care International) located at Defence Enclave Main Dichau Road, Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter No. Nil, dated 07.08.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 13.09.2024 in the presence of Sh. Satya, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of ground plus two upper floors, and following shortcomings observed: -

1. Two staircases having width of 1.50 & 1.22 m found provided against requirement width of 1.50 m each.
2. First aid hose reel/hydrant system found not provided.
3. MOEFA system found not provided.
4. Terrace fire pump of 450 LPM found not provided.
5. Water storage tank of 10,000 ltrs. found not provided.
6. Exit signage's are found not provided.

In view of above, fire safety certificate cannot be issued at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Anul Garg)
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.