



No. F6/DFS/MS/School/NDZ/2024/ 646

Dated: 19/09/2024

To,

The Principal,
The New Vidya Vihar Model School
F – 65, Dwarikapuri, Naveen Shahdara,
Delhi - 110032.

Subject: - Regarding grant of Fire Safety Certificate in r/o The New Vidya Vihar Model School located at F – 65, Dwarikapuri, Naveen Shahdara, Delhi - 110032.

Sir,

This has a reference to Email dated 22/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/09/2024 in the presence of Mrs. Girishma (Principal) and observed that building comprised of Basement, Stilt (Parking), upper ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.0 meter each are provided instead of required width of 1.50 meters each.
2. First-Aid-Hose Reel provided but not functional.
3. MOEFA not provided.
4. Internal Hydrant provided but not functional
5. Fire pump of 450 LPM provided but not functional.
6. Overhead tank of 5,000 liters capacity is provided against the requirement of 10,000 liters.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

ok 
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.