

c/90

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2024/ 603

Dated: 23/09/2024

To

The Joint Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/S Guest House Grand Peepal Located at Plot No.4/1, WEA Karol Bagh, New Delhi - 110005.

Sir,

Please refer to your Online Application No. 2024083113404, dated 31/08/2024, on the subject cited above. In this connection, it is to say that the aforesaid guest house has been inspected by the officer concerned of this department on 18.09.2024 in the presence of Mr. Manjeet Singh (Owner), to check the functional ability of fire safety arrangements already provided in the guest house building & Implementation of the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing guest house building.

During the inspection the following shortcomings are observed;-

- 1) Staircase found not clear
- 2) Fire Check Doors found not provided.
- 3) CO detectors not provided.
- 4) Terrace pump found nonfunctional.
- 5) Alarm system in lift car found nonfunctional.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter No F6/DFS/MS/GH/SZ/2022/116, dated 22/02/2022, is immediately suspended. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Copy to :-

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi
2. The Manager, M/S Guest House Grand Peepal Located at Plot No.4/1, WEA Karol Bagh, New Delhi - 110005.


(Atul Gang)
Director
Delhi Fire Service
01/4
19/9/24