

C 76

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/602

Dated: 20/09/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Hotel Gian Plaza situated at 759-761, S. P. Mukherjee Marg, Delhi - 110006.

Sir,

This has reference to online application I.D. no. 2024090713909 dated 07.09.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 13.09.2024 in the presence of Mr. Gian Chand Sharma (Owner) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm system provided but not functional.
2. PA system provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.
5. Occupancy of above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Anil Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
8/9 2024

**Copy to:-**

The Licensee,  
M/s Hotel Gian Plaza at 759-761, S. P. Mukherjee Marg, Delhi - 110006.