

C/71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 601

Dated:-20/09/2024

To,

The Manager,
M/S Sohana Palace Guest House,
2307-8-9, Chuna Mandi & 1590,
91, 92, 94 & 94 C, Main Bazar,
Pahar Ganj, Delhi.

Sub: Regarding renewal of FSC in r/o M/S Sohana Palace Guest House at 2307-8-9, Chuna Mandi & 1590, 91, 92, 94 & 94 C, Main Bazar, Pahar Ganj, Delhi.
Sir,

This has reference to your online id no. 2024082213030 dated 22.08.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 12/09/24 in presence of **Manager** and following shortcomings were observed:

1. Fire check doors are not provided at the staircase serving to basement.
2. Smoke management system is not provided on upper floors.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.