

C/06



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

Dated:- 26/09/2024

No. F6/DFS/MS/WZ/2024/ Sch | 660

To,

The Principal,
M.C. Primary Girls/Boys School,
Swan Park-I, Mundka, Delhi-110041.

Subj.:- Regarding issuance of Fire Safety Certificate in respect of M.C. Primary Girls/Boys School, located at Swan Park-I, Mundka, Delhi-110041.

Sir,

Please refer to your email dated 09/08/2024 on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 21/09/2024 in the presence of Ms. Sunita (Principal, Morning Shift) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/2014/713 dated 13/03/2014.

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, application for issuance of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to :-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/school/2014/713

Dated 13/03/14

To

The Principal,
M.C.D. Primary School (Girls)-I,
Swarn Park, New Delhi-110041.

Sub:- Inspection report in respect of M.C.D. Primary School (Girls)-I, Swarn Park,
New Delhi-110041 from Fire Safety point of view.

Sir,

Please refer to your letter No. Nil dated 26.12.2013 on the subject noted above, in this connection it is to inform you that the said school premises was inspected by the officer concerned of this department on 10.02.2014 in the presence of Smt. Nirmla Devi (Principal). To verify the shortcomings already issued by this department vide letter No. F6/DFS/MS/2012/ School/309 dated 01/02/2012.

During the course of inspection it was observed that the school premises comprised of **G + 2 upper floor only** with total covered area 1800yard² (600x3) built up on a plot area of 750 yard². School is approachable to fire units. Another school in the evening shift is also running in the same premises. All the class rooms are having double doors of 1.00mtr width each.

The fire safety arrangements such as 6 No. of fire extinguishers were seen provided in the premises.

However, following shortcomings were observed during the time of inspection:-

1. Only 6 fire extinguishers are provided which are inadequate. 3 more fire extinguishers are required to be provided.
2. First aid hose reel on each floor has not been provided.
3. A Fire pump of 450 Lts/minute capacity has not been provided.
4. Over Head Tank of 10,000 Lts. capacity not provided.
5. Exit signage not provided.

The School premises is not meeting the requirement of Fire & Safety guidelines issued by the Directorate of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011.

In view of above, Fire Safety Certificate from Fire Safety point of view cannot be considered at this stage. You are requested to approach for Fire Safety Certificate after compliance of above quoted fire safety guidelines.


(VIPIN KENTAL)
Dy. Chief Fire Officer,
Delhi Fire Service.
dcfowz.dlfire@nic.in
Ph: 011-23842505

