

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2024/ 544

Dated: 24/09 /2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 12, Block A,
Wazirpur Industrial Area, Delhi.

Sir,

Please refer your online request ID No.- 10118984 dated 12.09.2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at Plot No. 12, Block A, Wazirpur Industrial Area, Delhi.

Following shortcoming is observed:

1. Projection (corridors of MLCP) is overhanging above fire tender movement path, which is contravention of clause 8.2 of UBBL-2016.
2. Mixed occupancies (business and storage) are not separated by 240 minutes fire resistance rating as per clause 3.1.11 of NBC part IV, 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,

(Atul Garg)

Director

011-23414000

h e s