



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ 662

Dated:- 26/09/2024

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
S.P. Road, Nangloi, Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Sarvodaya Kanya Vidyalaya, located at S.P. Road, Nangloi, Delhi-110041.

Sir,

Please refer to your email dated 17/09/2021, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 21/09/2024 in the presence of Ms. Bhupendra (Teacher). During inspection, it has been observed that the school building is comprised of 02 block – Ground + 03 upper floors, 01 block - Ground + 02 upper floors & 01 block – Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. First Aid Hose Reels found non-functional.
2. Terrace pump of 450 lpm found non-functional.
3. Overhead water storage tank found empty.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Aml Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.