



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School2024/SZ/ 664

Dated: 26/09/2024

To

The Principal,
Vinay Nagar Bengali Sr. Sec. School,
A.K. Roy Marg, Sarojini Nagar
New Delhi-110023

Sub: Regarding issuance of observation report in r/o M/s Vinay Nagar, Bengali Sr. Sec. School A.K. Roy Marg, Sarojini Nagar, New Delhi-110023

Sir,

This is with reference to your letter No. VNBSSS/2024-25/FS/REN.LETTER/2024/3261 dated 13/09/2024 received vide outdoor diary No. 6588 dated 17/09/2024. In this connection, the desired report i.e. shortcomings observed and communicated by this office vide letter No. F.6/DFS/MS/School2024/SZ/546 dated 20/08/2024 is enclosed herewith.

This is for kind information and action at your end please.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 546

Dated: 20/08/2024

To

The Principal,
 Vinay Nagar Bengali Senior Secondary School,
 A.K. Roy Marg, Sarojini Nagar,
 New Delhi-110023

Sub: Inspection report in r/o Vinay Nagar Bengali Senior Secondary School, A.K. Roy Marg, Sarojini Nagar, New Delhi-110023 (School ID: 1719075)

Sir,

This has reference to your letter No. VNBSSS/2024-25/FS/Ren. Letter/2024/3184 dated 19/07/2024, received through outdoor diary No. 4349 dated 19/07/2024. In this connection, the premise was inspected by the officer concerned of this department on 08/08/2024 in your presence, from fire safety point of view. During course of inspection, the shortcomings observed are as below.

1. One of the staircases found obstructed by old wooden furniture.
2. First aid hose-reel found non-functional.
3. Terrace pump was not on auto mode and overhead tank found empty.
4. The exit signage found removed at some places.

In view of the above, application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054