

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/FH/2024/SZ/ 549

Dated: 25/09/2024

To

M/s Shagun Farm
Khasra No 25/5/6/15/16
Village-Jonapur, Mehrauli,
New Delhi 110047

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s Shagun Farm** located at Khasra No 25/5/6/15/16 Village-Jonapur, Mehrauli, New Delhi 110047.

Sir,

This has reference to with letter no nil dated nil received through outdoor diary no 6002 dated 03/09/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.09.2024 in the presence of Mr. Harshit Arora to verify the fire safety measures installed in the building and observed that the Farm House comprised of Basement, (Vacant) and Ground floor only. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The First Aid Hose reel provided but found non-functional.
2. The Internal Hydrant provided but found non-functional.
3. Fire Fighting pumps are provided but found non-functional.

The same observations has already been issued and communicated earlier by this department vide letter of even no 241 dated 07/12/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(APUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/mw