

d68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 605

Dated:-23/09/2024

To,

The Manager,
M/S A. P Hotels at 2216-17, Raj Guru, Road,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S A. P Hotels at 2216-17, Raj Guru Road, Pahar Ganj, New Delhi.

Sir,

This has reference to your online ID No. 2024082313063 dated 23.08.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 12/09/24 in presence of Mr. Ashwani and following shortcomings were observed:

1. Alternate staircase of 1.5 meter is not provided.
2. Corridor of 1.8 mtr width is not provided.
3. Regularized building plan of residential is uploaded on the portal whereas building plan of guest house of all floors including section/ elevation is required to be uploaded on the portal.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner , MCD, Civic Center, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.