



d92 75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/WZ/EH/2024/ 417

Dated: 25/09/2024

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub: - Inspection report in r/o M/s. Boussac (A Unit of NG Warehouse Pvt. Ltd.) Located at shop/property No. 13-C, Third Floor, NWA, Club Road, New Delhi -110026.

Sir,

This is in reference to the online application received through MHA portal vide ID-Online ID 2024082913320 dated 06/09/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 18/09/2024 in the presence Sh. Tarun Kumar (Manager) to check the fire safety arrangements/equipments provided in the building.

During the course of inspection, it was observed that the said restaurant is running at third floor in a building comprised of basement + stilt +ground + 3 upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, MOEFA, & etc provided. However, the following shortcomings were observed.

1. First Aid Hose Reel is provided but not functional.
2. MOEFA is provided but not functional.
3. Internal Hydrant is provided but not functional.
4. Main pump capacity of 2280 LPM, Jockey pump capacity of 180 LPM , Standby pump capacity of 2280 LPM & terrace level pump capacity of 450 LPM are provided but not functional.
5. Over head water storage tank capacity of 5000 ltrs is provided but found empty.
6. Exit Signages found removed.

In view of above Shortcomings, application of renewal of Fire safety Certificate cannot be considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Owner/ Occupier M/s. Boussac (A Unit of NG Warehouse Pvt. Ltd.) Located at Shop/property No. 13-C, Third Floor, NWA, Club Road, New Delhi -110026.
2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027.
Email Id : - (dhowest zone@gmail.com)

23/9/2024