dob

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI

No. F6/DFS/MS/SZ/2024/ EH 420

Dated: 26 109 12024

pal Garg)
Director

To.

The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.

Subject: Issuance of Fire Safety Certificate from fire safety point of view in r/o Darru Wala (A unit of Infralab Pvt. Ltd.) Located at Shop No. 4 to 8 & 35-36, Ground Floor Eros Metro Mall, Plot No 8, Sector – 14, Dwarka, New Delhi – 110078.

Sir,

Please refer to online application No. 2024090413698 dated-04/09/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 20/09/2024 in the presence of Sh. Tamandeep Singh from fire safety point of view.

During the course of inspection the flowing shortcomings are observed.

1. The kitchen found segregated by wooden partition from restaurant area. The kitchen must be segregated by two hours fire rating noncombustible material.

2. Exit signage found not provided.

3. Fire check down is not provided for entry in kitchen

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

2. The Manager, Darru Wala (A unit of Infralab Pvt. Ltd.) Located at Shop No. 4 to 8 & 35-36, Ground Floor Eros Metro Mall, Plot No 8, Sector – 14, Dwarka, New Delhi – 110078.