

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2024/SZ/ 406
To

Dated: 23/09/2024

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s Speciality Restaurants Ltd.** at E- 4, LSC, Masjid Moth, Greater Kailash -II, New Delhi - 110048

Sir,

This is in reference with **MHA Portal ID 2024082713193 dated 28/08/2024 & MHA Portal ID 2024081712811 dated 23/08/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 19/09/2024 in the presence of Mr. Kajal bishwas (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. First aid hose reel provided but found not functional.
2. Automatic sprinkler system provided but found not functional.
3. Internal hydrant provided but found not functional.
4. Fire fighting pumps provided but found not functional.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

07/09/24