

ch03

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F.6/DFS/MS/GH/WZ/2024 / 598

Dated 20 / 09 / 2024

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub:- Inspection report in respect of M/s. Hotel Jageer Palace, C-6/1, Main Road, Mansarovar Garden, New Delhi- 110015.

Sir,

Please refer to your Online Application ID. No. 2024072511602 dated 26/08/2024 on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 12/09/2024 in the presence of Sh. Pradeep Mishra to check the Fire safety arrangements.

During inspection, it was observed that the building is running at first floor (9 rooms), second floor (8 rooms) & third floor (8 rooms) floor of a building comprised of basement, ground plus three upper floors. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Pumping Arrangement & Exit Signage etc. However, following shortcomings were observed:-

1. First-Aid hose reel is provided but not functional.
2. Carbon Monoxide (CO) detectors are provided but not functional.
3. MOEFA is provided but not functional.
4. Public Address System is provided but not functional.
5. Automatic Sprinkler System is provided but not functional.
6. Terrace pump of capacity of 900 LPM is provided but not functional.
7. Overhead tank capacity of 2000ltr provided against requirement of 5000ltr.

In view of above shortcomings, the application for renewal fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier M/s. Hotel Jageer Palace, C-6/1, Main Road Mansarovar Garden, New Delhi- 110015.
2. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.


19/9/2024