

c/s0

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2024/ 418

Dated: 25/09/2024

To

The Manager,  
M/S Informal Restaurant,  
(A Unit of BEL CIBO Hospitality Pvt. Ltd.),  
Shop no. 52, Gr, & 1st Floor, Janpath, New Delhi.

**Sub: Regarding issuance of FSC in r/o M/S Informal Restaurant, (A Unit of BEL CIBO Hospitality Pvt. Ltd.), Shop no. 52, Gr, & 1st Floor, Janpath, New Delhi.**

Sir,

This has reference to online ID No. 2024082913298 dated: 29.08.2024, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 17/09/2024 in the presence of Manager and following shortcomings were observed:-

1. Alternate of exit found locked/ blocked.
2. First aid hose reel found nonfunctional.
3. Detector found nonfunctional.
4. Exit signages found removed.
5. Pump found nonfunctional.
6. Further, only ground floor plan is submitted, whereas all floor plans on which the establishment/ restaurant is situated is required to be uploaded on the portal.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed at this stage. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,  
New Delhi.