



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2024/SZ/ 610

Dated: 26 /09 /2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

**Sub: Inspection report in r/o M/s Pitrashish Pride Guest House situated at Khasra No. 98
Kapashera, New Delhi-110037**

Sir,

This has reference to online MHA ID No. 2024090113482 dated 04/09/2024. In this connection, it is to inform you that the said premise was visited by the officers concerned of this department on dated 18/09/2024 to verify status of the fire safety arrangements provided therein. Sh. Sharad Verma (Manager) was present at the time of inspection. During the inspection, the shortcomings observed are as below.

1. Fire check doors found removed.
2. Hose-reel found non-functional.
3. Automatic fire detection found non-functional & CO detector not provided.
4. Internal hydrant found non-functional.
5. Exit signage found removed at some places.
6. Lift signage found removed
7. Temporary shed on the terrace constructed in contravention of Clause 7.31 of UBBL.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Najafgarh Zone, Municipal Corporation of Delhi, Near Dhansa Bus Stand, Najafgarh, New Delhi-110043
2. Mr. Nishant Prakash, M/s Pitrashish Pride Guest House, Khasra No. 98 Kapashera, New Delhi-110037