

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/611
To

Dated: 26./09./2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Solo Victoria Guest House, C-8, Greater Kailash-1, New Delhi

Sir,

This has reference with **MHA Portal No 2024090513766 dated 05/09/2024 & 2024081412694 dated 14/08/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.09.2024 in the presence of Ms. Manish (Manager). Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

The same observations has already been issued and communicated earlier by this department vide letter no 538 dated 29/08/2024, letter of even no 152 dated 08/04/2024 & letter of even no 400 and 05/07/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE