



C/160
75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/WZ/EH/2024/ 415

Dated: 25/09/2024

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: - **Inspection report in r/o M/s. Troy Lounge and Bar (A unit of Shri Mahalaxmi Hospitality), Located at Plot no-19, 3rd Floor NWA, Club Road, Punjabi Bagh, New Delhi-110026.**

Sir,

This is in reference to the online application received through MHA portal vide ID-Online ID 2024090413664 dated 04/09/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 18/09/2024 in the presence Sh. Arun (Manager) to check the fire safety arrangements/equipments provided in the building.

During the course of inspection, it was observed that the said restaurant is running at third floor in a building comprised of basement + stilt + ground + 3 upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, Automatic fire detection and alarming system, MOEFA, Public Address System & etc provided. However the following shortcomings were observed.

1. First Aid Hose Reel is provided but not functional.
2. Automatic fire detection and alarming systems are provided but not functional.
3. MOEFA is provided but not functional.
4. Internal Hydrant is provided but not functional.
5. Main fire pump, Jockey Pump & Standby Pump is provided but not functional.
6. Over Head water storage tank capacity of 1, 00,000ltrs is provided but found empty.
7. Exit Signages found removed.

In view of above Shortcomings, application of renewal of Fire safety Certificate cannot be considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Owner/ Occupier Troy Lounge and Bar (A unit of Shri Mahalaxmi Hospitality), Located at Plot no-19, 3rd Floor NWA, Club Road, Punjabi Bagh, New Delhi-110026.
2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027.
Email Id : - (dhowest zone@gmail.com) — for taking in action as directed

23/9/2024