

C/86

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F6/DFS/MS/WZ/EH/2024/ 416

Dated: 25 10 9 /2024

To,  
The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s. TSRA Tradecorp LLP, Located at 37 Second & Third Floor, NWA, Club Road, West Punjabi Bagh, New Delhi-110026.

Sir,


This is in reference to the online application received through MHA portal vide ID- Online ID Online Application ID No. 2024072411535 dated 27/08/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 12/09/2024 in the presence Sh. Shaan sarin to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said restaurant/eating house is running at Second & Third floor in a building comprised of basement, ground & three upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, MOEFA, Overhead tank & Terrace Pump etc provided. However the following shortcomings were observed.

1. First Aid Hose reels and Internal Hydrants are provided but not functional.
2. Automatic smoke detection and alarming system is provided but not functional.
3. MOEFA is provided but not functional.
4. Terrace level Fire pump capacity of 450Lpm is provided but not functional.
5. Over Head water storage tank capacity of 3,000 ltrs is provided against requirement of 10,000ltrs.

In view of above Shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi-110027.(dhowest [zone@gmail.com](mailto:zone@gmail.com)).

2. The Owner/ Occupier M/s. TSRA Tradecorp LLP, Located at 37 Second & Third Floor, NWA, Club Road, West Punjabi Bagh, New Delhi-110026

  
23/9/2024