

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
 NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 674
 To

Dated: 03/10/2024

The Principal,
 Delhi Police Public School,
 B-4, Safdarjung Enclave,
 New Delhi 110029.

Sub: Regarding issuance of FSC in r/o M/s Delhi Police Public School, located at B-4, Safdarjung Enclave, New Delhi 110029.

Sir,

This has reference to your letter no DPPS/570 dated 05/09/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.09.2024 in the presence of Mr. Vivek Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Kitchen running under the staircase, which needs to be removed.
2. First Aid hose reel provided but found non-functional.
3. Automatic sprinkler system provided but found non-functional.
4. Internal hydrant provided but fund non-functional.
5. Terrace level fire fighting pumps capacity 900 LPM provided but found non-functional.
6. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


**(ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE**

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, old Secretariat New Delhi 110054.