

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE **NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/School/ 667

DATED: 27 /092024

To,

The Principal, G.D Goenka La Petite (Durga Education Society) Pocket - 03, Sector-17, Dwarka, New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o G.D Goenka La Petite (Durga Education Society) Located at Pocket - 03, Sector-17, Dwarka, New Delhi - 110075.

Sir,

Please refer to your letter No nil, dated 30/08/2024 on the subject cited above. In this connection it is to inform you that the above said premises was visited by the officer concerned of this department on 20/09/2024 in the presence of Mr. Gautam (Caretaker) to see the compliance of the shortcomings communicated vide this office letter No. F6/DFS/MS/SZ/2024/School/480, dated 30/07/2024 and found that the shortcomings are still not complied.

Apart from this it was observed that the stilt floor has been converted in office & children activity area. The stilt floor must be used as per approval of DDA/ MCD.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully.

Delhi Fire O

Copy to:-

- 1. The, Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-
- 2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
- 3. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI

No. F6/DFS/MS/SZ/2024/ School 480

Dated: 30 /07/2024

To,

The Principal, G.D Goenka La Petite (Durga Education Society) Pocket – 03, Sector-17, Dwarka, New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o G.D Goenka La Petite (Durga Education Society) Located at Pocket – 03, Sector-17, Dwarka, New Delhi - 110075.

Sir,

Please refer to your letter No. nil, dated 27/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 18/07/2024 in presence of Sh. Aditya Bansal (Owner) from fire safety point of view.

During the course of inspection following shortcomings are observed.

- 1. Hose reel hose & hydrants found nonfunctional.
- 2. PA system found nonfunctional.
- 3. Terrace fire pumps found nonfunctional and not in auto mode.
- 4. Exit signage's found removed at some places.
- 5. One room found erected at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

Copy to; -

The, Directorate Of Education Old Secretariat Delhi – 110054.