

456

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2024/ 671

Dated: 30/09/2024

To

The Vice Principal,  
Govt. Girls Senior Secondary School,  
Nicholson Road, Mori Gate, Delhi-110006.

**Sub:-** Regarding renewal of Fire Safety Certificate (FSC) in r/o Govt. Girls Senior Secondary School located at Nicholson Road, Mori Gate, Delhi-110006.

Sir,

This has reference to letter no. GGSSS/NICH RD/2024-25/168 dated 11.09.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned of this department on 19.09.2024 in the presence of Mrs. Nilmani Samad (Vice Principal) and it was observed that building is comprised of ground + 02 upper floors. During the inspection, following shortcomings were observed:-

1. Fire extinguishers provided but not functional.
2. Water storage tank provided is 5,000 ltr. against the requirement of 10,000 ltrs.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service  
Tel: 011-23414000

50  
24/9/2024

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.