

c/19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2024/ 672

Dated: 03/10/2024

To

The Principal,
Marwari Senior Secondary School,
Amir Chand Road, Nai Sadak, Delhi- 06.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o
Marwari Senior Secondary School, Amir Chand Road, Nai Sadak, Delhi - 06.**

Sir,

This has reference to your letter no. F/Fire/24-25/78 dated 07.09.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 25.09.2024 in the presence of Mr. P.B. Gupta (Principal) and observed that the building is comprised of ground + 03 upper floors but the school is running at 1st to 3rd floor only. During the inspection, following shortcomings still exists which issued earlier also vide letter no. F6/DFS/MS/2011/2056 dated 19/18/2011:-

1. One single staircase having width of 1.20 mtr exists against the requirement of width of 1.5 mtr. Hence, one additional staircase is required having width not less than 0.75 mtr. Extinguishers provided but non functional.
2. First aid hose reel at each floor not provided.
3. Public address system not provided.
4. One terrace fire pump capacity of 450 LPM + 40 mtrs. head not provided.
5. Over head water storage tank of 10,000 liters capacity is required exclusively for firefighting.
6. Exit signages are not adequately provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)

Director o/c

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.