

C/69

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 614

Dated: 01.10/2024

To,

The Manager,  
M/s Nine Street Guest House at 9390,  
Multani Dhanda, Pahar Ganj, New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Nine Street Guest House at 9390, Multani Dhanda, Pahar Ganj, New Delhi**  
Sir,

This has reference to your online id no. 2024090313615 dated 03.09.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 23/09/24 in presence of Mr. K.K. Singh and following shortcomings were observed:

1. Smoke management system is not provided.
2. CO detectors are not provided.
3. Hose reel found non functional.
4. Pump found non functional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.