

C/124

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/615

Dated: 01/10/2024

To,

The Manager,
M/s Rattan Deep Lodging House,
7864/3A, J-7879, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Rattan Deep Lodging House at 7864/3A, J-7879, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no.2024090313624 dated 03/09/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 23/09/24 in the presence of Manager and following shortcomings were observed: -

1. CO- detectors are not provided.
2. Smoke management system is not provided.

Hence, the case is rejected. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi.