



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ CC/333

Dated: 30/09/2024

To

Authorized Signatory  
Plot No- 42A/273, Ground Floor,  
Radio Colony, Delhi-110009

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sanskriti IAS Coaching Centre at Plot No-42A/273, Ground Floor, Radio Colony, Delhi-110009.

Sir,

Please refer to your letter no-nil dated 10.09.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 21.09.2024 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Nishant Saxena was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground & 03 upper floors, but coaching centre running at ground floor. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Hose reel hose is not provided.
2. Terrace level fire pump capacity of 450lpm is not provided.
3. Terrace level fire water tank capacity of 6000ltr is provided against the requirement of 10,000ltr.
4. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The Executive Engineer (Bldg.)-I, Rajpura Road, Civil Line Zone, Delhi.